



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 162.127/1/0

Expires: 05 December 2022

FIRE MONITOR AND NOZZLE

NAVUTEC
91-6, Sanden-3Ro Jeonggan-Eup
Busan
REPUBLIC OF KOREA

Style WM-80M mobile water monitor with 1300 lpm constant gallonage variable pattern nozzle.

Factory Mutual (FM) Report Project 3019375, Class 5511, dated 18 February 2005; Navutec Drawing No.NVT-WM-US80-00, Rev.03; and Protek service parts list for #823 nozzle dated 2011-05-05.

Approval is contingent upon compliance with the respective FM follow-up program and KR Hellas Ltd. quality system assessment.

The nozzle of this mobile water monitor meets the requirement of FM Standard 5511; the mobile water monitor assembly meets the guidelines of the Annex of IMO MSC.1/Circ. 1472.

*** End ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 05th DAY OF
DECEMBER 2017, AT WASHINGTON D.C.

B. A. BALDWIN
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT